

# HIGH WATER BILL?

## try the METER TEST

1. This test should be conducted for a 30 minute period, during which time no water is being used on the property.
2. Find your water meter, which is usually located in front of the house in a covered box near the street.
3. Write down the numbers indicated on the meter at the start of this test.
4. Return to check the meter reading after 30 minutes have passed.
5. If the numbers have not changed, you do not have a leak in your pressurized water system.
6. If the numbers have changed, continue with the following steps. Shut off the valves under all toilets in the house, and repeat steps 1-4.
7. If the numbers have not changed, you may have a running toilet that should be serviced.

If the numbers have changed, this indicates water consumption even though water was not being used during the test, and you may need a leak detection.

### *Do you have a question?*

*Call American Leak Detection and one of our expert leak specialists will be happy to help.*



**800.755.6697 • [www.americanleakdetection.com](http://www.americanleakdetection.com)**

© 2006 American Leak Detection